

# CERTIFICATE OF FLAME RETARDANCE

ISSUED TO: BERGAMO FABRICS  
P.O. BOX 231  
MOUNT VERNON, N.Y. 10561

NUMBER: #981291

DATE: 7-27-2003

THIS CERTIFICATE OF COMPLIANCE IS ISSUED TO VERIFY THAT THE ITEMS OR AREAS DESCRIBED BELOW ON THIS CERTIFICATE HAVE BEEN TREATED WITH FLAME CHECK™.

FLAME CHECK™ IS A CLASS A FIRE RETARDANT.

Description of Material, Structure, etc.


175 YARDS	BERGAMO FABRICS, TIFFANY WALLCOVERINGS	CALLIGRAH #5555
150 YARDS	BERGAMO FABRICS TIFFANY WALLCOVERINGS	CALLIGRAH #5555
223.05 YARDS	BERGAMO FABRICS TIFFANY WALLCOVERING, TRIANA	#4444
	A.S.T.M. E-84	
	7-31-2003	

ISSUED BY:

 **American  
Flamecoat  
Inc.**

10100 Park Cedar Dr. Suite 134  
Charlotte, NC 28210  
(704) 543-0903



  
Director GA-1201.01  
(General)

Note: Fabrics and/or materials described on this certificate are intended for interior use unless otherwise stated. Due to the number of external forces that can diminish flame retardancy, this fabric should be periodically retested to insure it retains its effectiveness. We do not warrant the length of time that the fabric remains fire retardant. We do state that when it leaves our facility, it meets the stated code. Certificate void if material is exposed to open flame or extremely hot lights or electrical wiring.