

CERTIFICATE OF FLAME RETARDANCE

LORI WEITZNER DESIGNS

ISSUED TO: 54 W. 21ST STREET
NEW YORK, NY 10010

NUMBER: #78329

DATE: 10-04-2013

THIS CERTIFICATE OF COMPLIANCE IS ISSUED TO VERIFY THAT THE ITEMS OR AREAS DESCRIBED BELOW ON THIS CERTIFICATE HAVE BEEN TREATED WITH FLAME COAT™.

FLAME COAT™ IS A CLASS A FIRE RETARDANT.

Description of Material, Structure, etc.

10	YARDS OF W1033 CURIO, TREATED W/FLAMECOAT
	A.S.T.M E-84, CLASS A
50131	10-04-2013

ISSUED BY:



521-F Eagleton Downs Drive
Pineville, NC 28134
(704) 543-0903



Director GA-1201.01
(General)

Note: Fabrics and/or materials described on this certificate are intended for interior use unless otherwise stated. Due to the number of external forces that can diminish flame retardancy, this fabric should be periodically retested to insure it retains its effectiveness. We do not warrant the length of time that the fabric remains fire retardant. We do state that when it leaves our facility, it meets the stated code. Certificate void if material is exposed to open flame or extremely hot lights or electrical wiring.